

**BANGLADESH RURAL ELECTIFICATION BOARD  
DHAKA, BANGLADESH.**

**PBS INSTRUCTION 300-45**

**SUBJECT: ELECTRIC SERVICE CONNECTION TO THE PREMISES OF HOUSEHOLD,  
COMMERCIAL, INDUSTRY, BRIDGE, FLY OVER, POWER PLANT, ETC.  
UNDER CONSTRUCTION.**

Date Of Approval : 29-07-1982  
Date Of Last Revision : 19-02-2020

**PURPOSE:**

To set forth the terms and conditions for providing electric service connection for the premises of household, commercial, industry, bridge, fly over, power plant, etc. under construction.

**POLICY:**

PBS will provide electric service facilities to the construction area of Household, Commercial, Industry, Bridge, Fly Over, Power Plant, Etc. under the following terms and conditions:

**A. Submission of Application:**


The consumer shall submit an application requesting a permanent electric service connection, specifying the time (month and year) when the connection would be taken, and stating the estimated load to be used by the above user. He will also mention his Construction load requirement during the construction period. On that basis, Consumer will sign an agreement with the PBS (as per attached appendix) keeping in view the PBS Instruction 300-4, 300-37, 100-35, 100-42 etc. according to BERC rate schedule/ Tariff order.

Revision:				
<b>BANGLADESH RURAL ELECTIFICATION BOARD</b>				
<b>PBS INSTRUCTION 300-45: PROVISIONAL ELECTRIC SERVICE CONNECTION TO PREMISES OF INDUSTRY UNDER CONSTRUCTION.</b>				
Original Date	Reviewed by	Approved by	Section &Page	Rev.No
29-07-1982	BREB	BREB Board	300-45-1	07 (02-2020)
Revision Dates: 30-05-1988, 26-06-1990, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 19-02-2020.				

  
(Md. Mozibur Rahman)  
Consultant TAPP BREB

  
(Md. Duhidul Islam)  
Consultant TAPP BREB

  
(Md. Mozammel Haq)  
Consultant TAPP BREB

  
(Md. Abdul Khaleque)  
Consultant TAPP BREB

  
(Md. Ansanul Haque)  
Consultant TAPP BREB

  
(Debanshi Chakraborty)  
PD, TAPP BREB

  
(Kamrul Absar Mollah)  
Asst. Secy. (Board), BREB

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০

**B. Building of Permanent Line Facilities:**

On the basis of declared load to be used by the Industry the PBS will extend service facilities on permanent basis up to the sub-station point of the consumer and therefore provisional connection will be given provided the provisional load. the line is to be constructed on deposit work. At the time of permanent connection, the deposited amount (line construction cost) will be adjusted against the monthly energy bill.

**C. Requirements During provisional Connection period:**

PBS will provide service facilities as per declared provisional load subject to strict compliance of the followings:

1. Contract Period:

Period of such contract will be limited to a maximum period of two years which may, however, be sparingly extended on a case-to-case basis for any further of time by the Bangladesh Rural Electrification Board on the recommendation of the Samity Board based on genuine and well-established grounds which are in their opinions, beyond the control of the consumer.

2. Supply Of Transformer:

PBS will supply Transformer for the provisional connection period subject to realization of the following charges:

- a) The consumer will pay, in advance, the Transformer cost and an installation and removal charge of Tk.2,000.00 ( Taka Two thousand) for single phase and Tk. 4,000.00 (Taka four thousand) only for three phase transformer bank.

Revision:				
BANGLADESH RURAL ELECTIFICATION BOARD				
PBS INSTRUCTION 300-45: PROVISIONAL ELECTRIC SERVICE CONNECTION TO PREMISES OF INDUSTRY UNDER CONSTRUCTION.				
Original Date	Reviewed by	Approved by	Section &Page	Rev.No
29-07-1982	BREB	BREB Board	300-45-2	07 (02-2020)
Revision Dates: 30-05-1988, 26-06-1990, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 19-02-2020.				

  
(Md. Mozibur Rahman)  
Consultant TAPP BREB

  
(Md. Duhidul Islam)  
Consultant TAPP BREB

  
(Md. Mozammel Huq)  
Consultant TAPP BREB

  
(Md. Abdul Khaleque)  
Consultant TAPP BREB

  
(Md. Ahsanul Haque)  
Consultant TAPP BREB

  
(Debasis Chakraborty)  
PD, TAPP BREB

  
(Kamrul Ahsan Mollik)  
Asst. Secy. (Board), BREB.

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০



b)

In Emergency aspect, the rent of Transformer (Max. 15 Days but in special case, Double rate in 30 days)	Transformer (11 KV) with Dropout Fuse cutout	300.00/Day
	Transformer (33 KV) with Dropout Fuse cutout	600.00/Day

**3. Capacity Of Transformer:**

Maximum Transformer capacity for provisional connection shall be as per consumer requirement.

**4. Damage or stolen Cases:**

It is to be mentioned in the Agreement that the materials or equipment used for the purpose of provisional connection by PBS, if lost or damaged or stolen, the entire cost of the same will be realized from the consumer before re-connection.

**5. Energy rate and Demand charge:**

The Rate Schedule under this category will be the following:

LT- C 2: The consumers of Household, Commercial, Industry, Bridge, Fly Over, Power Plant, etc. upto 50 KW will be under this Rate Schedule category.

MT- 4: The consumers of above 50 KW up to 5 MW load will be under the category of MT- 4 as per approved load demand.

HT- 4: The consumers of above 5 MW up to 30 MW load will be under the category of HT- 4 as per approved load demand.

Revision:				
BANGLADESH RURAL ELECTIFICATION BOARD				
PBS INSTRUCTION 300-45: PROVISIONAL ELECTRIC SERVICE CONNECTION TO PREMISES OF INDUSTRY UNDER CONSTRUCTION.				
Original Date	Reviewed by	Approved by	Section &Page	Rev.No
29-07-1982	BREB	BREB Board	300-45-3	07 (02-2020)
Revision Dates: 30-05-1988, 26-06-1990, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Haq)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP BREB

(Md. Anisul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
PD, TAPP BREB

(Kamrul Ahsan Mollik)  
Asst. Secy. (Board), BREB.

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০

এলটি-সি ২ঃ নির্মাণ

১. ৫০ কিলোওয়াট পর্যন্ত অনুমোদিত চাহিদা সম্বলিত সকল নির্মাণ কাজে (যথা-আবাসন, বাণিজ্যিক ও শিল্প স্থাপনা, ব্রীজ, ফ্লাই ভার, বিদ্যুৎ কেন্দ্র ইত্যাদি) বিদ্যুৎ ব্যবহার এ গ্রাহক শ্রেণির অন্তর্ভুক্ত হবে।
২. ৫০ কিলোওয়াট থেকে সর্বোচ্চ ৩০ মেগাওয়াট পর্যন্ত অনুমোদিত চাহিদা সম্বলিত এরূপ বিদ্যুৎ ব্যবহার নির্ধারিত অনুমোদিত চাহিদার ভিত্তিতে এমটি-৪ অথবা এইচটি-৪ এর অন্তর্ভুক্ত হবে।
৩. নির্মাণ কাজ সমাপ্তিতে নির্ধারিত প্রক্রিয়ায় নির্মাণ সংযোগ যথাযথ শ্রেণিতে রূপান্তর করা হবে।

6. Security Deposit:

The consumer will pay in addition to all charges an advance security deposit on provisional load (required during construction period only) and this will be calculated as per BERC Rule. If the consumer fails to take permanent connection by supplying his own transformer as per declared load within the stipulated period, the entire advance deposit, will be forfeited and the connection will be disconnected.

7. Adjustments of Advances:

Payment of advances and dues from the consumer to the PBS and vice versa are subject to final adjustment on the basis of actual consumption and cost incurred.

8. Capacity retention charges:


The consumer will have to pay the capacity retention charge, as calculated according to 300-04, until permanent connection is made.


Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS INSTRUCTION 300-45: PROVISIONAL ELECTRIC SERVICE CONNECTION TO PREMISES OF INDUSTRY UNDER CONSTRUCTION.				
Original Date	Reviewed by	Approved by	Section & Page	Rev.No
29-07-1982	BREB	BREB Board	300-45-4	07 (02-2020)
Revision Dates: 30-05-1988, 26-06-1990, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 19-02-2020.				

  
(Md. Mozibur Rahman)  
Consultant TAPP BREB

  
(Md. Duhidul Islam)  
Consultant TAPP BREB

  
(Md. Mozammel Haq)  
Consultant TAPP BREB

  
(Md. Abdul Khaleque)  
Consultant TAPP BREB

  
(Md. Ahsanul Haque)  
Consultant TAPP BREB

  
(Debasish Chakraborty)  
PD TAPP BREB

  
(Kamrul Ahsan Mollik)  
Asst. Secy. (Board), BREB.

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০



ATTACHMENT OF PBS INSTRUCTION 300-45

Agreement for provisional Electric Service  
(Under Construction Industry)

Agreement -----, 20 -----, between ----- Palli Bidyut Samity  
----- (hereinafter called the "PBS"), and -----  
(hereinafter called the "Consumer") a -----,  
(Corporation, Partnership or individual)

The PBS will sell and deliver to the consumer, and the consumer shall purchase all Electric power and energy which the consumer may need at the location described in Exhibit "A", attached hereto and by this reference made a part hereof upon the following terms and conditions:

1. Service Characteristics and Conditions:

- (a) Service hereunder shall be alternating current ----- phase, ----- wire, fifty cycles, ----- volts. Provisional load ----- kw (kva X 0.95)
- (b) Service hereunder shall be furnished on a Provisional basis not to exceed twenty four (24) months durations, beginning with the initial billing period following the date PBS first makes Service available.
- (c) Service hereunder shall be furnished on basis of Consumer's declared load requirements of the under construction industry, with permanent electric facilities being extended up to the consumer designated sub-station location.

Revision:				
BANGLADESH RURAL ELECTIFICATION BOARD				
PBS INSTRUCTION 300-45: PROVISIONAL ELECTRIC SERVICE CONNECTION TO PREMISES OF INDUSTRY UNDER CONSTRUCTION.				
Original Date	Reviewed by	Approved by	Section & Page	Rev.No
29-07-1982	BREB	BREB Board	300-45-5	07 (02-2020)
Revision Dates: 30-05-1988, 26-06-1990, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP, BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Haq)  
Consultant, TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP BREB

(Md. Ahsanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
PD TAPP BREB

(Kamrul Ahsan Mollik)  
Asst. Secy. (Board), BREB.

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০

