

**BANGLADESH RURAL ELECTRIFICATION BOARD**  
**DHAKA, BANGLADESH**  
**PBS INSTRUCTION: 300-04**

**SUBJECT: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.**

Date of Approval : 28-05-1984  
Last Revision : 19-02-2020

**PURPOSE :** To establish and set forth policy guidelines and procedures to be followed in order to conduct a feasibility study and issue a consent letter for new electric connection, shifting of services, shifting of poles/lines and issue of assurance certificate for availability of electricity for proposed industries.

**POLICY:** The Palli Bidyut Samity shall agree to conduct feasibility studies and intimate the prospective applicant the possibility of providing new connection, modification of lines and retention of load etc. upon fulfillment of the following procedures, Terms and Conditions.

**PROCEDURES, TERMS AND CONDITIONS**

**A. NEW CONNECTION (PERMANENT/TEMPORARY)**

1. This procedure shall be applicable to new connection, both Permanent and Temporary.
2. Each applicant of the aforesaid category requesting for an Electric connection must submit an application as per format attached in **Appendix-B.**

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-1	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Huq)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP BREB

(Md. Ahsanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
PD, TAPP/BREB

(Kamrul Ahsan Mollah)  
Asst. Secy. (Board), BREB

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০

3. (a) Application fee for new connection (for each meter):

SL No.	Category	Description	rate
01	LT	a) Single phase	Tk.100
		b) Three phase	Tk.300
02	MT and HT		Tk.1000
03	EHT		Tk.2000

- (b) Application fee for temporary connection (for each meter):

SL No.	Category	Description	rate
01	LT	a) Single phase	Tk.250
		b) Three phase	Tk.500
02	MT		Tk.1000

- (c) Each application, whether domestic, irrigation or others, shall be made separate.

4. (a) Upon receipt of such application and fee PBS will carry out a preliminary field survey and technical study by the Member Service department. Updated staking sheets and updated transformer cards are to be attached with the technical study report. In case these are not available, pertinent information such as pole number, voltage level at that pole, wire size, transformer location and rating, single line diagram or sketch of LT lines showing pole-wise number and type of services, span lengths, conductor size and phase, distance of applied connection from nearest pole, etc. are to be provided along with the field survey report to be prepared by PBS. On completion of field survey by the PBS (PSR) and for the cases where connection is feasible, Member Service Department will forward, if necessary, the preliminary survey report with pertinent information to the Local Engineering Consultant/RE for Technical Study (TSR) or staking or both. If it is found feasible to provide connection of proposed load, then the PBS will issue a first information letter of electric connection to the applicant.

However, if the proposed connection is within service drop distance than the application shall not be forwarded to the consultant.

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-2	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Haq)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP, BREB

(Md. Ahsanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
D.TAPP BREB

(Kamrul Ahsan Mollik)  
Asst. Secy. (Board), BREB,

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০



(b) সংযোগ সহজীকরণঃ

সংযোগ সহজীকরণের লক্ষ্যে প্রযোজ্য ক্ষেত্রে (লাইন নির্মাণ/ সংযোগ সুবিধা সৃষ্টি ব্যতীত) ০৭ দিনে আবাসিক এবং ২৮ দিনে শিল্প সংযোগের জন্য সম্ভাব্য গ্রাহকদেরকে যে সকল প্রয়োজনীয় কাগজপত্র জমা প্রদান করতে হবে তা'দেয়া হলঃ

০১। আবাসিক নতুন বৈদ্যুতিক সংযোগ এর জন্য প্রয়োজনীয় ডকুমেন্ট এর তালিকা

(সকল সংস্থা/কোম্পানির জন্য প্রযোজ্য)

- (০১) ২ কপি পাসপোর্ট সাইজের ছবি
- (০২) জাতীয় পরিচয় পত্র/ পাসপোর্টের ফটোকপি
- (০৩) জমির মালিকানা দলিল বা লিজ ডিড বা নামজারীর কাগজ, মূল মালিক না থাকলে উত্তরাধিকার সনদ
- (০৪) পূর্বের সংযোগ থাকলে পরিশোধিত বিলের কপি ( একই নামে বা স্থানে আরো সংযোগ নিতে নতুন করে আর কোন ডকুমেন্টস লাগবে না)
- (০৫) বহুতল ভবনের (১০ তলার অধিক) ক্ষেত্রে অগ্নি নির্বাপন সার্টিফিকেট
- (০৬) রাজউক/সিডিএ/কেডিএ/আরডিএ এবং অন্যান্য ক্ষেত্রে সিটি কর্পোরেশন/পৌরসভার অনুমোদিত বিল্ডিং প্ল্যান, হোল্ডিং নম্বর (প্রযোজ্য ক্ষেত্রে)

বিঃদ্রঃ২ (দুই) কিঃ ওঃ এর অধিক লোড এর ক্ষেত্রে সোলার প্যানেল স্থাপনের সার্টিফিকেট লাগবে।

২। বাণিজ্যিক নতুন বৈদ্যুতিক সংযোগ এর জন্য প্রয়োজনীয় ডকুমেন্ট এর তালিকা

(সকল সংস্থা/কোম্পানির জন্য প্রযোজ্য)

- (০১) ২ কপি পাসপোর্ট সাইজের ছবি
- (০২) জাতীয় পরিচয় পত্র/ পাসপোর্টের ফটোকপি
- (০৩) জমির মালিকানা দলিল বা লিজ ডিড বা নামজারীর কাগজ, মূল মালিক না থাকলে উত্তরাধিকার সনদ
- (০৪) পূর্বের সংযোগ থাকলে পরিশোধিত বিলের কপি ( একই নামে বা স্থানে আরো সংযোগ নিতে নতুন করে আর কোন ডকুমেন্টস লাগবে না)
- (০৫) বহুতল ভবনের (১০ তলার অধিক) ক্ষেত্রে অগ্নি নির্বাপন সার্টিফিকেট
- (০৬) রাজউক/সিডিএ/কেডিএ/আরডিএ এবং অন্যান্য ক্ষেত্রে সিটি কর্পোরেশন/পৌরসভার অনুমোদিত বিল্ডিং প্ল্যান, হোল্ডিং নম্বর (প্রযোজ্য ক্ষেত্রে)

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-3	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Huq)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP BREB

(Md. Ahsanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
TAPP BREB

(Kamrul Ahsan Mollik)  
Asst. Secy. (Board) BREB

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০

(০৭) এইচ টি (H.T) সংযোগের ক্ষেত্রে বৈদ্যুতিক লাইসেন্সিং বোর্ডের সার্টিফিকেট ও মিটার রুমের লে-আউট প্ল্যান।

বিঃদ্রঃ প্রযোজ্য ক্ষেত্রে সোলার প্যানেল স্থাপনের সার্টিফিকেট লাগবে।

**৩। শিল্প সংযোগ এর জন্য প্রয়োজনীয় ডকুমেন্ট এর তালিকা**

(সকল সংস্থা/কোম্পানির জন্য প্রযোজ্য)

- (০১) ২ কপি পাসপোর্ট সাইজের ছবি
- (০২) জাতীয় পরিচয় পত্র/ পাসপোর্টের ফটোকপি
- (০৩) জমির মালিকানা দলিল বা লিজ ডিড বা নামজারীর কাগজ, মূল মালিক না থাকলে উত্তরাধিকার সনদ
- (০৪) পূর্বের সংযোগ থাকলে বিল পরিশোধের কপি (একই নামে বা স্থানে আরো সংযোগ নিতে নতুন করে আর কোন ডকুমেন্টস লাগবে না)
- (০৫) বহুতল ভবনের (১০ তলার অধিক) ক্ষেত্রে অগ্নি নির্বাপন সার্টিফিকেট
- (০৬) রাজউক/সিডিএ/কেডিএ/আরডিএ এবং অন্যান্য ক্ষেত্রে সিটি কর্পোরেশন/পৌরসভার অনুমোদিত বিল্ডিং প্ল্যান, হোল্ডিং নম্বর (প্রযোজ্য ক্ষেত্রে)
- (০৭) এইচটি (H.T) সংযোগের ক্ষেত্রে বৈদ্যুতিক লাইসেন্সিং বোর্ডের সার্টিফিকেট ও মিটার রুমের লে-আউট প্ল্যান।
- (০৮) শিল্প ও ক্ষুদ্র শিল্প হিসেবে নিবন্ধন সার্টিফিকেট ( এই ডকুমেন্টটি বাদ দেয়া যেতে পারে)

বিঃদ্রঃ প্রযোজ্য ক্ষেত্রে সোলার প্যানেল স্থাপনের সার্টিফিকেট লাগবে।

**৪। শিক্ষা প্রতিষ্ঠান/ধর্মীয় প্রতিষ্ঠান/সেবামূলক প্রতিষ্ঠান/হাসপাতাল এ সংযোগের ক্ষেত্রে প্রয়োজনীয় ডকুমেন্ট এর তালিকা**

- (০১) পাসপোর্ট সাইজের ছবি
- (০২) জাতীয় পরিচয় পত্রের ফটোকপি (মনোনিত ব্যক্তির)
- (০৩) জমির মালিকানা দলিল বা লিজ ডিড বা নামজারীর কাগজ, মূল মালিক না থাকলে উত্তরাধিকার সনদ (প্রযোজ্য ক্ষেত্রে)

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-4	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Huq)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP BREB

(Md. Ansanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
PD, TAPP, BREB

(Kamrul Ansan Moirah)  
Asst. Sec

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০



- (০৪) পূর্বের সংযোগ থাকলে বিল পরিশোধের কপি (প্রযোজ্য ক্ষেত্রে)  
 (০৫) রাজউক/সিডিএ/কেডিএ/আরডিএ এবং অন্যান্য ক্ষেত্রে সিটি কর্পোরেশন/পৌরসভার অনুমোদিত বিল্ডিং প্ল্যান, হোল্ডিং নম্বর (প্রযোজ্য ক্ষেত্রে)  
 (০৬) বহুতল ভবনের (১০ তলার অধিক) ক্ষেত্রে অগ্নি নির্বাপন সার্টিফিকেট (প্রযোজ্য ক্ষেত্রে)

বিঃদ্রঃ প্রযোজ্য ক্ষেত্রে সোলার প্যানেল স্থাপনের সার্টিফিকেট লাগবে।

**৫। সামাজিক বা বাণিজ্যিক কর্মকাণ্ডের জন্য বা নির্মাণ কাজের জন্য অস্থায়ী সংযোগের ক্ষেত্রে প্রয়োজনীয় ডকুমেন্ট এর তালিকা**

- (০১) পাসপোর্ট সাইজের ছবি (মনোনিত ব্যক্তির)  
 (০২) জাতীয় পরিচয় পত্রের ফটোকপি (মনোনিত ব্যক্তির)  
 (০৩) সামাজিক বা বাণিজ্যিক কর্মকাণ্ডের জন্য কর্তৃপক্ষের অনুমতিপত্র  
 (০৪) ডেভেলপার কর্তৃক ভবন নির্মাণ করা হলে ভূমির মালিক কর্তৃক প্রদত্ত পাওয়ার অফ এটর্নি

**৬। সেচ সংযোগের ক্ষেত্রে প্রয়োজনীয় ডকুমেন্ট এর তালিকা**

- (০১) পাসপোর্ট সাইজের ছবি  
 (০২) জাতীয় পরিচয় পত্রের ফটোকপি  
 (০৩) সেচ কমিটির অনুমোদনপত্র

**B. SHIFTING/REROUTING OF POLE, LINE AND SERVICE DROPS**

1. This procedure shall be observed for setting the applications by a consumer or a non-consumer within the PBS area for shifting of poles, Rerouting of Line Alignments, Shifting/Rerouting of Service Drops installed by PBS.
2. The reasons for such modifications shall be realistic and genuine. This modification will be regretted if they are not technically feasible.
3. Each applicant of the aforesaid category requesting for Shifting/Rerouting of Poles, Lines and Service Drops must submit an application as per format attached in Appendix-E.

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-5	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Haq) (Md. Abdul Khaleque)  
Consultant TAPP BREB Consultant TAPP BREB

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০

(Md. Ahsanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
PD, TAPP, BREB

(Kamrul Ahsan Mollik)  
Asst. Secy. (Board), BREB.

4. Each applicant whether an individual or a group shall deposit a non-refundable inspection fee as per Rule of BERC as specified in the respective form of application attached here to.
5. **For shifting/re-routings of service drops within same transformer each applicant shall deposit a non-refundable disconnection & reconnection fee as per Rule of BERC as specified in the respective form attached here to being the cost to be incurred by Palli Bidyut Samity during site investigation.**
6. Upon receipt of such application and fee PBS will carry out a preliminary field survey and technical study by the Member Service department. The technical study to be conducted by PBS shall contain a sketch showing existing and proposed arrangements, On completion of field survey & technical study PBS Member Service Department send the report to Local Engineering Consultant/RE for TSR of staking with estimate or both and if it is found feasible to carry out the applied modification, then the PBS will issue a first information letter along with an estimate prepared by Consultant/RE indicating the amount to be deposited by the applicant before PBS take up the job.
7. The aforesaid modifications shall be taken up within a least possible time after the applicant deposits the estimated amount being the cost of applied modifications.

**C. ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATE**

1. The following procedures shall be applicable for Industrial consumers and Organizations having Complexes seeking Assurance of Electricity Availability Certificates.
2. Each applicant requesting for "Assurance of electricity Availability Certificate" must submit an application as per format attached in **Appendix-A**.
3. The industrial Applicant requesting an "Assurance of Electricity availability certificate" shall have to submit one complete set of plans and specifications of the proposed Industry which must contain detailed and comprehensive drawings of all Electrical Installations and requirements.
4. Each applicant shall deposit a non-refundable fee amounting to Taka 1,000.00 (One thousand) only also specified in the form of application attached hereto being the cost to be incurred by the PalliBidyutSamity during site investigation and Engineering feasibility study.

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-6	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP BREB

(Md. Ahsanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
PD, TAPP BREB

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০

(Kamrul Ahsan Mollah)  
Asst. Secy. (Board), BREB.



5. Upon receipt of such application and fee PBS will carry out a preliminary field survey and technical study by the Member Service Department Updated staking sheets and updated transformer cards are to be attached with the technical study report. In case these are not available or required, pertinent information such as pole number, voltage level at that pole, wire size, transformer location and rating, single line diagram or sketch of LT lines showing pole-wise number and type of services, span lengths, conductor size and phase, distance of applied connection from nearest pole, etc, are to be provided along with the technical report to be prepared by PBS. On completion of field survey (PSR) by the PBS, Member Service Department will forward, if necessary, to the Local Engineering Consultant/RE for technical study (TSR). If it is found feasible to provide connection of proposed load, then the PBS will issue a first information letter (as per format **appendix-C**) of Assurance of Electricity Availability Certificate to the applicant on payment of capacity retention charges.
6. In normal situations Assistant General Manager, Member Services will issue Assurance of Electricity Availability Certificates provided the PBS system has adequate sub-station and feeder spare capacity.
7. If the review and feasibility study indicates that there exists adequate sub-station and feeder circuit capacity, the PBS will issue a first information letter of "Assurance of Electricity Availability Certificate" to the applicant for such period as the applicant may solicit, But in any case the assurance period will not be less than 6 (six) months or not more than two years for the first time.
8. The validity of "Assurance of Electricity Availability Certificate" may be extended from time to time for such period as the applicant may solicit but not exceeding two years upon payment of additional capacity-Retention Charges so calculated for the extended period as per section D(1).
9. In any applicant fails to utilize the assurance within two years period effective from first date of assurance, the respective applicant's Assurance of Electricity Availability Certificate may be extended for further period of maximum two years (3<sup>rd</sup> and 4<sup>th</sup> years) provided that there exists adequate sub-station and feeder circuit capacity and subject to payment of Capacity Retention Charge as per section D(2).
10. Due to unavoidable circumstances, if further extension (after four years) of the Assurance of Availability of Electricity Certificate is required, then on request from the applicant(s), the PBS will refer the case through board

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-7	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mazammel Hossain)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant, TAPP, BREB

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০

(Md. Ahsanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
PO, TAPP BREB

(Kamrul Ahsan Mollah)  
Asst. Secy (TAPP BREB)



proposal with justification to **BREB** for approval. If approved, the capacity retention charges will be as per rate stated in Section D(2).

11. Each "Assurance of electricity Availability Certificate" will be issued as per format attached in **Appendix-D** covering the information such as: The name of the proposed Industry, Site, Total Load, specific date of validity of assurance.
12. The validity of the "Assurance of Electricity Availability Certificate" will be treated as cancelled if the Applicant fails to take electric connection or renew the period of validity within the date of validity stated in the certificate.
13. Applicant holding the "Assurance of Electricity Availability Certificate" will have to deposit the cost of deposit work (if applicable), at least three months prior to the schedule date of taking provisional/permanent connections (which ever may be the case & earlier) so that PBS may complete the construction of required Line extension and other works as per PBS Policies and Guidelines, After completion of wiring Inspection report by the PBS for provisional/permanent connection, the applicant will have to deposit the refundable money (security deposit) calculated on provisional/permanent load and then contract to be signed-up between the PBS and the applicant for provisional/permanent connection.

#### D. CAPACITY RETENTION CHARGE

1. For obtaining Electricity Availability Certificate, the applicant will pay the capacity-retention charges of entire period in advance. At the beginning, the Capacity Retention charge shall be: **Tk. 5.00 (Taka Five only)** per KVA of load of the proposed load for each month's validity of Assurance of Electricity Availability certificate with a minimum of tk. **500.00 (Taka Five Hundred only)** per applicant per month or it's fraction.
2. If any applicant fails to utilize the assurance within two years period effective from first date of assurance, the respective applicant's assurance of Electricity Availability Certificate may be extended for further period of maximum two years on payment of Capacity Retention Charge which shall be: Tk. 10.00 (Taka Ten) per KVA of load per month with a minimum of Tk. 1,000.00 (Taka One Thousand only) per applicant per month or it's fraction.

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-8	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Huq)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP BREB

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০

(Md. Ahsanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
PD, TAPP BREB

(Kamrul Ahsan Mollik)  
Asst. Secy. (Board) BREB



3. The capacity retention charges will be applicable upto the date of permanent connection. The Capacity Retention Charge shall be on total load under assurance whether provisional connections has been taken or not. The provisional connection will not exempt an applicant from paying Capacity Retention Charges.
4. The Capacity Retention Charges will be applicable for (i) Provisional Connection and (ii) Assurance of Electricity Availability Certificate, only.

**E. FEASIBILITY STUDY AND REVIEW.**

1. For every application as mentioned in A,B,C above a feasibility study (PSR/TSR) either by the Member Service Department or by the Consultant/RE has to be carried out. Every application must be both technically and financially viable.
2. If the case needs thorough and detailed study, then the PBS will refer the application to Local engineering Consultant/RE to accomplish the following on priority basis:
  - a) Review & study of the sub-station and distribution feeder circuit capacity (which will be used in supplying electric power to the applicant) in order to determine if reserve capacity (if any) will be adequate with the sub-station and feeder circuit to meet the requested Load requirements of the applicant.
  - b) Amount of new construction (in terms of span) or Line conversion required in order to connect the proposed Industry.
  - c) All other relevant determining areas of technical and engineering study required in order to meet the request for supply of power and energy to the applicant consumer.
3. If the review and study report of the local Engineering Consultant indicates that there does not exist adequate sub-station and Feeder circuit capacity, the PBS with the following information and all pertinent data shall request **BREB** System Engineering and Design Directorate for their suggestions and comments and necessary action in this regard.
  - a) Existing capacity of the sub-station/feeder circuit.
  - b) Existing consumption of Load from the Sub-station capacity, Feeder circuit capacity.
  - c) Existing Load reserve of the sub-station/feeder circuit.

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-9	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Haq)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP BREB

(Md. Ansanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
PD. TAPP BREB

(Kamrul Ahsan Mollah)  
Asst. Secy. (Board), BREB.

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০

- d) Required Load for the Applicant consumer from the sub-station/Feeder circuit.
- e) Requirement of enhancement of existing sub-station/Feeder circuit capacity.
- f) The Assistant General Manager, Operation & Maintenance (O&M) or the Assistant General Manager, Engineering & Construction (E&C) where Assistant General Manager (E&C) has been placed, shall maintain a feeder-wise, sub-station-wise records of the committed loads for the approved Electricity Availability Certificates, The Consultant shall also maintain and update such records for this purpose and engineering studies.

4. BREB System Engineering and design Directorate shall review the request together with the basic information and data and may instruct the Senior General Manager/General Manager of the concern PBS to approve the request on the basis of the future expansion program in the said PBS, or may advise the Senior General Manager/General Manager to regret the application for the time being if there does not exist such immediate program. SE&D Directorate, however, shall take measure for immediate augmentation of Capacity for the PBS depending on its need and will intimate the PBS about its future expansion plans and program. On the basis of the recommendations of BREB SE&D Directorate, the PBS will issue/regret to issue such a consent letter of electric connection or Assurance of Electricity Availability Certificate to the concerned Applicant(s).

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-10	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Huq)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP BREB

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০

(Md. Ahsanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
PD, TAPP BREB

(Kamrul Ahsan Mollik)  
Asst. Secy. (Board), BREB.



জেনারেল ম্যানেজার

.....পল্লী বিদ্যুৎ সমিতি.....

বিষয়ঃ প্রতিষ্ঠান/শিল্প প্রতিষ্ঠানের বিদ্যুৎ সংযোগ/বিদ্যুৎ সংযোগ সম্মতি পত্রের জন্য আবেদন।

জনাব,

উল্লেখিত বিষয়ে নিম্নস্বাক্ষরকারী.....পল্লী বিদ্যুৎ সমিতি.....এর যাবতীয়  
বিধিবদ্ধ নিয়ম প্রতিপালন ও সমিতির সহিত নির্দিষ্ট সংযোগ চুক্তিপত্র স্বাক্ষর করিতে সম্মত হইয়া নিম্নবর্ণিত  
তথ্যাদি অবহিত করণ পূর্বক সংযোগের জন্য আগ্রহী।

এমতাবস্থায়, বর্ণিত প্রতিষ্ঠান/শিল্প প্রতিষ্ঠানে বিদ্যুৎ সংযোগ/বিদ্যুৎ সংযোগ প্রাপ্তির সম্মতি পত্র প্রদান করার জন্য  
অনুরোধ জানাচ্ছি।

প্রস্তাবিত প্রতিষ্ঠান/শিল্প সম্পর্কিত তথ্যাদি

- ০১। আবেদনকারীর নাম (প্রধান কর্মকর্তা ও জন্ম তারিখ)
- ০২। আবেদনকৃত প্রতিষ্ঠানের নাম :
- ০৩। পিতা বা স্বামীর নাম (প্রযোজ্য হলে) :
- ০৪। আবেদনকারীর ঠিকানা :
- ক) স্থায়ী :
- খ) বর্তমান :
- ০৫। প্রস্তাবিত বিদ্যুৎ সংযোগ স্থলের বর্ণনা :
- (ক) সম্পত্তির আইনগত মালিকের নাম :
- (খ) উপজেলা.....(গ) ইউনিয়ন:.....
- (ঘ) গ্রাম.....(ঙ) মৌজা:.....
- (চ) দাগ নং-.....(ছ) খতিয়ান নং-.....
- (জ) বিদ্যুৎ লাইনের নিকটবর্তী খুঁটি হইতে দূরত্ব:.....মিটার/ফুট
- ০৬। প্রস্তাবিত সংযোগের ধরণ :
- ০৭। আবেদন পত্রের প্রকৃত : (ক) স্থায়ী সংযোগের জন্য/ (খ) সাময়িক সংযোগের জন্য/  
(গ) বিদ্যুৎ সংযোগ বিষয়ক সম্মতি পত্রের জন্য

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-11	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mazhar Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Huq)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP BREB

(Md. Ahsanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
OD, TAPP BREB

(Kamrul Ahsan Mollik)  
Asst. S. BREB

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০

- ০৮। চাহিদাকৃত লোড : .....  
 (ক) স্থায়ী সংযোগ লোড চাহিদা.....কিঃ ওঃ/কেভিএ.....ফেজ.....ভোল্ট।  
 স্থায়ী সংযোগের সময়.....মাস  
 (খ) সাময়িক সংযোগ লোড.....কিঃ ওঃ/কেভিএ.....ফেজ.....ভোল্ট।  
 যে তারিখে সংযোগ প্রয়োজন.....স্থায়িত্ব.....মাস  
 (অপর পৃষ্ঠা দ্রষ্টব্য)

## Appendix-A

পবিস নির্দেশিকা ৩০০-৪

- ৯। প্রতিষ্ঠানের আইনগত প্রকৃতি : ব্যক্তি মালিকানা/প্রাইভেট লিঃ কোং/পাবলিক লিঃ কোং/  
 সমবায়/আধা সরকারী/সরকারী স্বায়ত্বশাসিত।  
 ১০। বিদ্যুৎ সংযোগ জনিত চুক্তির ব্যাপারে আইনানুগ ভারপ্রাপ্ত কর্মকর্তার নাম ও পদবী:  
 ১১। অন্য কোন তথ্য প্রদান করিতে চাহিলে:

তারিখ: \_\_\_\_\_

আবেদনকারীর স্বাক্ষর ও পদবী

### নিম্নের তথ্যাদি অফিস কর্তৃক পূরণীয়

- ০১। প্রাথমিক রিপোর্টে (সদস্য সেবা বিভাগ কর্তৃক) :  
 (সর্বোচ্চ ৭ দিনের মধ্যে)  
 ০২। ষ্টেকিং শীটের সূত্রসহ পরামর্শদাতা প্রকৌশলীর মন্তব্য :  
 (সর্বোচ্চ ৭ দিনের মধ্যে)  
 ০৩। এজিএম (ইএন্ডসি/ওএন্ডএম)/প্রকল্প বিভাগের মন্তব্য :  
 (লাইন নির্মানের তারিখ)  
 ০৪। জেনারেল ম্যানেজারের নির্দেশ :

জেনারেল ম্যানেজার

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-12	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Huq)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP BREB

(Md. Ansanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
D.O. TAPP, BREB.

(Kamrul Ansan Mollik)  
Asst. Secy (Board) BREB.

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০



শর্তাবলীঃ

- (১) আবেদন করার সময় আবেদনকারীকে বিদ্যুৎ সংযোগের জন্য প্রাথমিক সমীক্ষা সম্পাদনের জন্য টাকা ১০০০.০০ (এক হাজার) মাত্র সমিতির এর অনুকূলে নগদ জমা দিতে হইবে (অফেরৎযোগ্য)।
- (২) শিল্প প্রতিষ্ঠানের লে-আউট প্ল্যানসহ প্রস্তাবিত বৈদ্যুতিক যন্ত্রপাতির অবস্থান সম্পর্কিত ড্রইং ও বিস্তারিত বিবরণ জমা দিতে হইবে।
- (৩) সাময়িক সংযোগ এবং বৈদ্যুতিক লোডের নিশ্চয়তা চাওয়া হইলে এবং সমিতি কর্তৃক এতদসংক্রান্ত সম্মতিপত্র জারী করা হইলে সংরক্ষণ ফি স্থায়ী সংযোগ হওয়া প্রযোজ্য হইবে।

Appendix-B  
পবিস নির্দেশিকা ৩০০-৪

জেনারেল ম্যানেজার

.....পল্লী বিদ্যুৎ সমিতি.....

বিষয়ঃ বাড়ি/বাণিজ্যিক/দাতব্য প্রতিষ্ঠান/সেচ প্রকল্প/অস্থায়ী বিদ্যুৎ সংযোগের জন্য আবেদন।

জনাব,

উল্লেখিত বিষয়ে নিম্নস্বাক্ষরকারী.....পল্লী বিদ্যুৎ সমিতি.....এর যাবতীয় নিয়ম প্রতিপালনে সম্মত হইয়া নিম্নবর্ণিত তথ্যাদি অবহিত করণ পূর্বক সংযোগের জন্য আগ্রহী।

এমতাবস্থায়, নিম্নবর্ণিত স্থানে বাড়ী/বাণিজ্যিক/দাতব্য প্রতিষ্ঠান/সেচ প্রকল্প/অস্থায়ী সংযোগের বিষয়ে প্রয়োজনীয় ব্যবস্থা গ্রহণ করিয়া বাধিত করিবেন।

তথ্য সমূহ

- ০১। আবেদনকারীর নাম ও জন্ম তারিখ :
- ০২। পিতা/স্বামীর নাম :
- ০৩। আবেদনকারীর ঠিকানা :
- ক) স্থায়ী :
- খ) বর্তমান :

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB. Board	300-4-13	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Huq) (Md. Abdul Khaleque)  
Consultant TAPP BREB Consultant, TAPP, BREB

(Md. Ahsanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
PD, TAPP BREB

(Kamrul Ahsan Mollah)  
Asst. Secy. (Board), BREB

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০

- ০৪। প্রস্তাবিত সংযোগ স্থলের বর্ণনা :  
 (ক) সম্পত্তির আইনগত মালিকের নাম :  
 (খ) উপজেলা.....(গ) ইউনিয়ন:.....  
 (ঘ) গ্রাম.....(ঙ) মৌজা:.....  
 (চ) দাগ নং.....(ছ) খতিয়ান নং.....  
 (জ) বিদ্যুৎ লাইনের নিকটবর্তী খুঁটি হইতে দূরত্ব:.....মিটার/ফুট
- ০৫। বৈদ্যুতিক লোডের ধরণ :  
 ০৬। বৈদ্যুতিক লোড :.....ওয়াট/ কিঃ ওঃ/অশ্বশক্তি  
 ০৭। সংযোগের প্রকৃতি :.....ফেজ.....ভোল্ট.....সাইকেল  
 ০৮। সেচ কার্যের ক্ষেত্রে :.....ডিপ-টিউবওয়েল/স্যালো টিউব-ওয়েল/এল,এল,পি  
 ০৯। সংযোগের তারিখ (প্রস্তাবিত) :  
 ১০। আবেদনকারী অন্য কোন তথ্য প্রদান করিতে চাহিলে :  
 তারিখ:..... আবেদনকারীর স্বাক্ষর ও পদবী

(অপর পৃষ্ঠা দ্রষ্টব্য)

## Appendix-B

পবিস নির্দেশিকা ৩০০-৪

### নিম্নের তথ্যাদি অফিস কর্তৃক পূরণীয়

- ০১। প্রাথমিক রিপোর্টে (সদস্য সেবা বিভাগ কর্তৃক) :  
 (সর্বোচ্চ ৭ দিনের মধ্যে)  
 ০২। স্টেকিং শীটের সূত্রসহ পরামর্শদাতা প্রকৌশলীর মন্তব্য :  
 (সর্বোচ্চ ৭ দিনের মধ্যে)  
 ০৩। এজিএম (ইএন্ডসি/ওএন্ডএম)/প্রকল্প বিভাগের মন্তব্য :  
 (লাইন নির্মানের তারিখ)  
 ০৪। জেনারেল ম্যানেজারের নির্দেশ :

জেনারেল ম্যানেজার

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-14	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Huq)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant, TAPP, BREB

(Md. Ansanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
PD, TAPP, BREB

(Kamrul Ahsan Molla)  
Asst. Secy. (Board) BREB

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০



**শর্তাবলীঃ**

(১) বাড়ী/বাণিজ্যিক/দলগত/দাতব্য প্রতিষ্ঠানের বিদ্যুৎ সংযোগের জন্য নিম্নবর্ণিত হারে সমীক্ষা ফি আবেদনের সহিত জমা দিতে হইবে।

(ক) ১ হইতে ৯ জন পর্যন্ত গ্রাহকের ক্ষেত্রে : ২৫.০০ টাকা (জনপ্রতি)

(খ) ১০ হইতে ২০ জন পর্যন্ত গ্রুপ সম্বলিত : ২৫০.০০ টাকা (নির্ধারিত)

গ্রাহকের ক্ষেত্রে

(২) সেচ কার্যে বিদ্যুৎ সংযোগের জন্য আবেদনের সহিত টাঃ ২৫০.০০ (দুইশত পঞ্চাশ) মাত্র সমীক্ষা ফি জমা প্রদান করিতে হইবে। সংযোগের চুক্তি সম্পাদনের প্রাক্কালে আবেদনকারীর ০২ (দুই) কপি ছবি জমা দিতে হইবে।

(৩) ১ নং ও ২ নং এ উল্লিখিত উভয় লোডের জন্য একই অবস্থানে একটি আবেদন পত্র ব্যবহারের ক্ষেত্রে সমীক্ষা ফি বাবদ সর্বসাকুল্যে ২৫০.০০ (দুইশত পঞ্চাশ) টাকা জমা প্রদান করিতে হইবে।

(৪) যে কোন ধরনের অস্থায়ী সংযোগের জন্য ২৫০.০০ টাকা (দুইশত পঞ্চাশ) টাকা সমীক্ষা ফি বাবদ জমা দিতে হইবে।

(৫) বর্ণিত সংযোগ ও শিল্প প্রতিষ্ঠান ব্যতীত অন্য কোন সাময়িক/স্থায়ী সংযোগের ক্ষেত্রে ২৫০.০০ টাকা (দুইশত পঞ্চাশ) টাকা সমীক্ষা ফি বাবদ জমা দিতে হইবে।

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-15	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Huq)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP BREB

(Md. Ahsanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
P.D. TAPP BREB

(Kamrul Ahsan Molla)  
Asst. Secy. (D. & E.) BREB

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০

(পল্লী বিদ্যুৎ সমিতির ঠিকানা)

স্মারক নং-.....

তারিখঃ-.....

জনাব/মেসার্স.....

বিষয়ঃ বিদ্যুৎ সংযোগের জন্য লোড সংরক্ষণ সম্মতিপত্র প্রদান সংক্রান্ত।

সূত্রঃ আপনার ..... তারিখের আবেদন পত্র।

বর্ণিত বিষয় ও সূত্রের প্রেক্ষিতে নিম্নবর্ণিত শর্তাদি প্রতিপালন স্বাপেক্ষে প্রস্তাবিত সর্বোচ্চ কেভিএ/কিলোওয়াট লোডের জন্য বিদ্যুৎ সংযোগের সম্মতিপত্র প্রদান করা যেতে পারে।

- ১। প্রতি কেভিএ প্রতি মাস ২.৫০ টাকা হিসাবে লোড সংরক্ষণ ফি দিতে হবে। তবে কোন অবস্থাতেই প্রতি মাসে ২৫০.০০ টাকার কম হবে না।
- ২। সর্বনিম্ন ৬ মাস এবং সর্বোচ্চ ২ বছরের জন্য সম্মতি-পত্র প্রদান করা যাবে।
- ৩। গ্রাহকের আবেদনের প্রেক্ষিতে আরও দুই বৎসর (অর্থাৎ তৃতীয় ও চতুর্থ বৎসর) এর জন্য লোড সংরক্ষণ সম্মতি পত্র প্রদান করা হবে যদি লোড সংরক্ষণের সুবিধা থাকে। এই ক্ষেত্রে লোড সংরক্ষণ ফি প্রতি মাসে প্রতি কেভিএ ৫.০০ টাকা (পাঁচ টাকা) এবং কোন অবস্থাতেই প্রতি মাসে ৫০০.০০ টাকার (পাঁচশত টাকার) কম নহে।
- ৪। যে কয় মাসের জন্য লোড সংরক্ষণ করতে ইচ্ছুক, সংরক্ষণের পূর্বে সকল মাসের ফি একত্রে সমিতিতে জমা প্রদান করতে হবে এবং টাকা জমা প্রদানের তারিখ হতে লোড সংরক্ষণ কাযকরী হবে।
- ৫। লোড সংরক্ষণের সময় বর্ধিত করতে, হলে সম্মতি পত্রের মেয়াদ শেষ হওয়ার পূর্বেই পুনরায় সংরক্ষণের জন্য নির্দিষ্ট হারে অর্থ সমিতিতে জমা প্রদান করে অনুমতি গ্রহণ করতে হবে। অন্যথায় নির্দিষ্ট তারিখের পর হতে সম্মতি পত্র বাতিল বলে বিবেচিত হবে।
- ৬। লোড সংরক্ষণকারী শিল্প/শিল্প কমপ্লেক্সে বিদ্যুৎ সংযোগ গ্রহণের ক্ষেত্রে নিম্নরূপ অর্থ সমিতির অনুকূলে জমা প্রদান করতে হবে।

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-16	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Huj)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP BREB

(Md. Ahsanul Haque)  
Consultant TAPP BREB

Debasis Chakraborty  
PD. TAPP BREB

(Kamrul Ahsan Mollik)  
Asst. Secy. (Board) BREB

৬২১ ভম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০



- (ক) সাময়িক/স্থায়ী (যাহা পূর্বে ঘটবে) সংযোগ গ্রহণের কমপক্ষে তিন মাস পূর্বে লাইন নির্মাণ খরচ (প্রয়োজনে) সমিতির অনুকূলে জমা প্রদান করতে হবে।
- (খ) সংযোগ লোড ১৫০ কেভিএ এর উর্ধ্বে হলে স্থাপন খরচসহ ট্রান্সফর্মার শিল্প মালিককে সরবরাহ করতে হবে (সমিতিতে পর্যাপ্ত মজুদ থাকলে সমিতি থেকে ট্রান্সফর্মার ক্রয়/ভাড়া গ্রহণযোগ্য।

(অপর পৃষ্ঠা দ্রষ্টব্য)

-২-

## Appendix-C

পবিস নির্দেশিকা ৩০০-৪

- (ঘ) শিল্প কর্তৃপক্ষ কর্তৃক সম্পন্নকৃত ওয়্যারিং সমিতি কর্তৃক পরিদর্শন ও এতদসংক্রান্ত গ্রহণযোগ্য সনদপত্র প্রদানের পর অন্ততঃ সংযোগ গ্রহণের ৫ (পাঁচ) দিন পূর্বে নির্ধারিত হারে নিরাপত্তা জামানত সমিতির অনুকূলে জমা প্রদান করতে হবে।
- ৭। উপরোক্ত শর্তাবলীর কোন পরিবর্তন হলে তৎসহ অত্র প্রতিষ্ঠানের বিদ্যুৎ সংযোগ সম্পর্কিত নির্ধারিত বিধি বিধান এই শিল্প সংযোগের লোড সংরক্ষণের শর্ত হিসাবে গন্য হবে।
- ৮। চুক্তি সম্পাদনের প্রাক্কালে আবেদনকারীর ০২ (দুই) কপি ছবি জমা দেওয়া প্রয়োজন হইবে।

সহকারী মহা-ব্যবস্থাপক (সদস্য সেবা)

বরাবর,

জনাব/মেসার্স.....  
.....  
.....

অনুলিপিঃ

- ১। সহকারী মহা-ব্যবস্থাপক (অর্থ)..... পবিস.....।

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-17	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP, BREB

(Md. Duhidul Islam)  
Consultant TAPP BRE

(Md. Mozammel Huq)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP, BREB

(Md. Ahsanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
TAPP BREB

(Kamrul Ahsan Mollik)  
Asst. Secy.

৩২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০

(পল্লী বিদ্যুৎ সমিতির ঠিকানা)

স্মারক নং-.....

তারিখঃ-.....

বিষয়ঃ বিদ্যুৎ সংযোগের জন্য লোড সংরক্ষণ সম্মতিপত্র।

এই মর্মে প্রত্যায়ন করা যাইতেছে যে, নিম্নে উল্লেখিত প্রস্তাবিত শিল্প/শিল্প কমপ্লেক্সে নিম্নবর্ণিত শর্তানুযায়ী অত্র সমিতির বিদ্যুৎ বিতরণ ব্যবস্থা হইতে বিদ্যুৎ সংযোগ দেওয়ার জন্য..... তারিখ পর্যন্ত লোড সংরক্ষণ করা হইলঃ

- ১। শিল্প/শিল্প কমপ্লেক্স এর নাম :
- ২। শিল্প/শিল্প কমপ্লেক্সের অবস্থান :  
(ক) দাগ নং-..... মৌজা/গ্রাম:.....  
ইউনিয়ন:..... উপজেলা:.....  
জেলা:.....  
(খ) বিদ্যুৎ লাইনের নিকটবর্তী খুঁটি হইতে দূরত্ব:..... মিটার/ফুট
- ৩। সংরক্ষণকৃত লোড..... কিঃ ওঃ/কেডিএ..... ফেজ..... ভোল্ট..... সাইকেল।
- ৪। উল্লেখিত পরিমাণ লোডে বিদ্যুৎ সংযোগের এ সম্মতি পত্র কেবলমাত্র..... তারিখ পর্যন্ত বলবৎ থাকিবে।
- ৫। উপরোক্ত শর্তাবলীর কোন পরিবর্তন হইলে তৎসহ অত্র প্রতিষ্ঠানের বিদ্যুৎ সংযোগ সম্পর্কিত নির্ধারিত বিধি বিধান এই শিল্প সংযোগের লোড সংরক্ষণের শর্ত হিসাবে গন্য হবে।

সহকারী মহা-ব্যবস্থাপক (সদস্য সেবা)

বরাবর,

জনাব/মেসার্স.....  
.....  
.....

অনুলিপিঃ

- ১। সহকারী মহা-ব্যবস্থাপক (অর্থ)..... পবিস.....।

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-18	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Haq)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP BREB

(Md. Ansanul Haque,  
Consultant TAPP BREB

(Debasish Chakraborty)  
PD, TAPP BREB

(Kamrul Ansan Mollik)  
Asst. Secy. (Road) BREB.

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০



জেনারেল ম্যানেজার

.....পল্লী বিদ্যুৎ সমিতি.....

বিষয়ঃ পোল স্থানান্তর/লাইন রুট পরিবর্তন/ সার্ভিস ড্রপ রুট পরিবর্তনের জন্য আবেদন।

জনাব,

উল্লেখিত বিষয়ে নিম্নস্বাক্ষরকারী.....পল্লী বিদ্যুৎ সমিতি.....এর যাবতীয় নিয়ম প্রতিপালনে সম্মত হইয়া নিম্নবর্ণিত তথ্যাদি অবহিত করণ পূর্বক আমরা অসুবিধা সৃষ্টিকারী পোল/লাইন/ সার্ভিস ড্রপ স্থানান্তরের আবেদন করিতেছি।

এমতাবস্থায়, বিষয়টি সরেজমিনে তদন্ত পূর্বক প্রয়োজনীয় ব্যবস্থা গ্রহণ করিয়া বামিত করিবেন। উল্লেখ্য যে, এই জন্য সমিতি কর্তৃক ধার্যকৃত ফি প্রদানে আমি সম্মত আছি।

তথ্য সমূহ

- ০১। আবেদনকারীর নাম :
- ০২। পিতা/স্বামীর নাম :
- ০৩। আবেদনকারীর ঠিকানা :
- ক) স্থায়ী :
- খ) বর্তমান :
- ০৪। প্রার্থীর স্থানান্তর/পরিবর্তন স্থানের বর্ণনা :
- (ক) উপজেলা.....(খ) ইউনিয়ন:.....
- (গ) গ্রাম.....(ঘ) মৌজা:.....
- (ঙ) দাগ নং-.....(চ) খতিয়ান নং-.....
- ০৫। বৈদ্যুতিক লোডের ধরণ : এলটি/এইচটি/সার্ভিস
- ০৬। আবেদনের কারণ: (ক) চলাচলের বিঘ্ন ঘটাইতেছে।
- (খ) জমির উপর দিয়া অতিক্রম করিয়াছে।
- (গ) ঘরবাড়ি/শিল্প প্রতিষ্ঠান নির্মাণে বিঘ্ন ঘটাইতেছে।
- (ঘ) উন্নয়নমূলক কাজের সুবিধার্থে।
- (ঙ) নিরাপত্তার অভাব।
- (চ) অন্যান্য:.....

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
PBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-19	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Huq)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP BREB

(Md. Ahsanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
TAPP BREB

(Kamrul Ahsan Molla)  
Asst. Secy. (Board) BREB

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০

- ৭। আবেদনকারী সমিতির সদস্য কি না? : .....
- ৮। অন্য কোন তথ্য প্রদান করিতে চাহিলে :

তারিখ: \_\_\_\_\_

আবেদনকারীর স্বাক্ষর ও পদবী

(অপর পৃষ্ঠা দ্রষ্টব্য)

## Appendix-E

পবিস নির্দেশিকা ৩০০-৪

### নিম্নের তথ্যাদি অফিস কর্তৃক পূরণীয়

- ০১। প্রাথমিক রিপোর্টে (সদস্য সেবা বিভাগ কর্তৃক) :  
(সর্বোচ্চ ৭ দিনের মধ্যে)
- ০২। স্টেকিং শীটের সূত্র প্রাক্কলনসহ পরামর্শদাতা প্রতিষ্ঠানের :  
প্রকৌশলীর মন্তব্য  
(সর্বোচ্চ ৭ দিনের মধ্যে)
- ০৩। এজিএম (ইএলসি/ওএলএম)/প্রকল্প বিভাগের মন্তব্য :  
(কার্য সম্পাদনের সম্ভাব্য তারিখ)
- ০৪। জেনারেল ম্যানেজারের নির্দেশ :

জেনারেল ম্যানেজার

#### শর্তাবলীঃ

- (১) পোল স্থানান্তর/লাইন রুট পরিবর্তন/সমিতি কর্তৃক স্থাপিত অন্য গ্রাহকের সার্ভিস ড্রপ স্থানান্তরের আবেদনের সহিত অফেরৎযোগ্য টাকা ২৫০.০০ (দুইশত পঞ্চাশ) মাত্র সমীক্ষা ফি সমিতির অনুকূলে জমা দিতে হইবে।
- (২) কারিগরী কারণে স্থানান্তর অথবা রুট পরিবর্তন সম্ভব না হইলে আবেদন বিবেচনা করা হইবে না।
- (৩) সমিতি কর্তৃক হিসাবকৃত প্রাক্কলন আবেদনকারী কর্তৃক জমাদানের পরপরই কাজ হাতে নেয়া হইবে।

Revision:				
BANGLADESH RURAL ELECTRIFICATION BOARD				
FBS Instruction 300-04: NEW ELECTRIC CONNECTION, ASSURANCE OF ELECTRICITY AVAILABILITY CERTIFICATES, SHIFTING OF POLES/LINES/SERVICES.				
Original Date	Reviewed by	Approved by	Section & Page	Rev. No
28-05-1984	BREB	BREB Board	300-4-20	7 (02/2020)
Revision Dates: 25-03-1986, 31-08-1992, 31-10-1996, 24-12-2013, 29-04-2014, 04-05-2014, 19-02-2020.				

(Md. Mozibur Rahman)  
Consultant TAPP BREB

(Md. Duhidul Islam)  
Consultant TAPP BREB

(Md. Mozammel Huq)  
Consultant TAPP BREB

(Md. Abdul Khaleque)  
Consultant TAPP BREB

(Md. Ahsanul Haque)  
Consultant TAPP BREB

(Debasish Chakraborty)  
CD. TAPP BREB

(Kamrul Ahsan Monir)  
Asst. Secy. (D. & A) BREB

৬২১ তম বোর্ড সভায় অনুমোদিত সিদ্ধান্ত নং ১৭৭০০