



২০-

Schedule-2

PRICE SCHEDULE FOR GOODS  
TO BE OFFERED FROM WITHIN THE PURCHASER'S COUNTRY

1	2	3	4	5	6
Item	Description	Country of Origin	Quantity	Unit Price (including all VAT/TAX & Transportation etc.)	Total Price
					4×5
1	1-Phase Smart Prepayment Meter with RF Mesh Communication Module.		25000		


  
মোঃ মোইনুল হোসেন উদ্দিন  
বিজিএম (প্রশাসন)  
ফাইল নং-৫২৩২৩৭  
ঢাকা পবিস-১


  
মোহাম্মদ আব্দুল জব্বার মিয়া  
বিজিএম (সদর দপ্তর-কারিগরী)  
ঢাকা পবিস-১

**Sub: Response against queries of Hexing Electrical Co., Ltd for Design, Supply, Testing and Commissioning of 25,000 Nos 1-Phase Smart Prepayment Meter with RF mesh Communication Module.**

Ref: Sub-Package No: 23-24-DHKPBS-1. O&M-01

Section/ Clause of TD	Page Number	Provision of tender document	Queries from Bidders	Response of BREB
Notice	N/A	Design, Supply, Testing and Commissioning of 25,000 Nos 1-Phase Smart Prepayment Meter with RF Mesh Communication Module. <b>ITT 1.2</b> The number, identification and name of lots comprising the Tender is 25,000 Nos 1-Phase Smart Prepayment Meter with RF Mesh Communication Module.	Please clarify whether this tender is Turn-Key Basis or only meter supply? Based on Turn-Key Basis or meter supply, please remove related tender requirement and clauses which is not required for this tender.	ITT-1.2, GCC 24.1, GCC 41.1 will be replaced as "This tender is only for supplying of 25000Nos of single phase smart prepayment meter with RF mesh communication Module which is inter operable with existing DCU."
Section-02	38	<b>GCC 24.1</b> The time for completion of the delivery of goods including 25,000 Nos 1-Phase Smart Prepayment Meter with RF Mesh Communication Module as per delivery schedule -6 whole of the facilities within from the effective date as described in the contract agreement. <b>GCC 41.1</b> The time for completion of the delivery of goods including installation, commissioning & testing as per delivery schedule-6		
Section-04	101	<b>ITT 14.1(b)</b> d) The tenderer shall furnish manufacturer authorization for offered major items like Smart pre-payment meter (single phase and three phases), DCU server/computer, storage (SAN), router & Service Cable.	In our understanding the offered major items shall be only Single phase meter. Three Phase, DCU, Server/Computer, Storage (SAN), Router& Service Cable these items are not mentioned in Schedule No. 1 and List of Goods and Delivery Schedule as offered items. Please clarify and amend accordingly.	Manufacturer authorization is required for meter and module.
Section-02	39			
Section-05	117	Schedule No-1 1-Phase Smart Prepayment Meter With RF Mesh Communication Module.		

  
 গাজিয়া (অংশীদার)  
 মাহিউল নূর-৫২৩২৩৭  
 ঢাকা পবিস-১

  
 মোহাম্মদ আব্দুল জলিল শিমা  
 ডিজিএম (সদর নজর-কারিগরি)  
 ঢাকা পবিস-১

Sub: Response against queries of Hexing Electrical Co., Ltd for Design, Supply, Testing and Commissioning of 25,000 Nos 1-Phase Smart Prepayment Meter with RF mesh Communication Module.

Ref: Sub-Package No: 23-24-DHKPBS-1. O&M-01

Section/ Clause of TD	Page Number	Provision of tender document	Queries from Bidders	Response of BREEB
Section-02 to Section-07	39-224	<p>ITT14.1(b)</p> <p>f) The manufacturer shall have supply record of major hardware items like Pre-Payment meter (single phase and three phases), for last 5(Five) calendar years.</p> <p>g) The manufacturer shall have 2nos. Performance Certificate from the End User for the major hardware items like Smart Pre-Payment meter (single phase and three phases) within last 05(Five) calendar years.</p>	<p>We have reviewed tender document and found Three Phase Meter requirement in several places. In our understanding this tender requirement should be only for Single Phase Meter. Please clarify and amend accordingly</p>	<p>This tender is only for single phase smart prepayment meter with RF mesh communication Module.</p>
Section-07	198-217	<p>Specification for Three Phase Online Smart Prepayment Energy Meters.</p>	<p>Please clarify which form name is correct PG4-4 or PG5A-4a?</p>	<p>Form PG4-4 for "Specification of 230 Volt 5(60) A Single Phase Smart Prepayment Meter of page No 129 of tender document should be followed for this tender.</p>
Section-02	39	<p>ITT14.1(b)</p> <p>e) The tenderer and respective manufacturer shall fill up Specifications Submission &amp; Compliance Sheet (PG4-4) for offered goods with appropriate data,</p>		
Section-05	105	<p>Tender form PG5A-4a Specification Submission and compliance sheet</p>		
Section-02	40	<p>ITT14.1(b)</p> <p>k) Interfacing: The system software has been developed and erected. The prescribed interfacing protocol has been developed in JAVA which is attached in part-2 of the tender document.</p>	<p>Please provide us Part-2. In tender document we couldn't find Part-2.</p>	<p>Part-2 has been attached</p>

গোহাঙ্গাং জিঞ্জিমা  
গোহাঙ্গাং (খোশাংগি)  
ফোন নং-৫২৩২৩৯  
ঢাকা পবিস-১



গোহাঙ্গাং আব্দুল জব্বার মিয়া  
জিঞ্জিমা (সরদার-কাজিগারী)  
ঢাকা পবিস-১



৬৪

Sub: Response against queries of Hexing Electrical Co., Ltd for Design, Supply, Testing and Commissioning of 25,000 Nos 1-Phase Smart Prepayment Meter with RF mesh Communication Module.

Ref: Sub-Package No: 23-24-DHKPBS-1. O&M-01

Section/ Clause of TD	Page Number	Provision of tender document	Queries from Bidders	Response of BREB
Section-02	41	Joint Venture(JV) will not be allowed  Tender submission Letter for Technical Offer (Form PG5A-1a) g) we, including as applicable any JVCA partner, declare that we are not associated, nor have been associated in the past, directly or indirectly, with a consultant or any other entity that has prepared the design, specifications and other documents in accordance with ITT Sub Clause 5.5; k) we, including as applicable any JVCA partner, confirm that we do not have a record of poor performance, such as abandoning the works, not properly completing contracts, inordinate delays, or financial failure as stated, in ITT Clause 5.7, and that we do not have, or have had, any litigation against us, other than that stated in the Tenderer Information (Form PG5A-2b);  Attachment-2 [ITT Sub Clause 29.2(b)] Copy of the JVCA Agreement / Letter of Intent to form JVCA with draft proposed Agreement Tender submission Letter for Financial Offer (Form PG5A-1b) h) we, including as applicable any JVCA partner, declare that we are not associated, nor have been associated in the past, directly or indirectly, with a consultant or any other entity that has prepared the design, specifications and other documents in accordance with ITT Sub Clause 5.5; j) we, including as applicable any JVCA partner, confirm that we do not have a record of poor performance, such as abandoning the works, not properly completing contracts, inordinate delays, or financial failure as stated in ITT Clause 5.7, and that we do not have, or have had, any litigation against us, other than that stated in the Tenderer Information (Form PG5A-2b);	Please clarify why JVCA is not allowed for turkey tender.	As per provision of tender document
Section-05	107-111			



স্বাক্ষরিত (স্বাক্ষরিত)  
১৩/০৬/১৯

১৩/০৬/১৯



স্বাক্ষরিত (স্বাক্ষরিত)  
১৩/০৬/১৯

১৩/০৬/১৯

**Sub: Response against queries of Hexing Electrical Co., Ltd for Design, Supply, Testing and Commissioning of 25,000 Nos 1-Phase Smart Prepayment Meter with RF mesh Communication Module.**

Ref: Sub-Package No: 23-24-DHKPBS-1. O&M-01

Section/ Clause of TD	Page Number	Provision of tender document	Queries from Bidders	Response of BREB		
Section-02	41	ITT 24.2(r) iii) The tenderer shall have to submit the Authorization Letter from data network service provider at their letter head pad as confirmation.	Network service is not mentioned or isn't scope of work for this tender so please clarify if we are required to provide Authorization Letter from data network service provider.	Authorization Letter from data network service provider is not required.		
Section-04	101	GCC 38.2 I. For Smart meter, FAT/PSI will be conducted by 05 Engineers from BREB/PBS for minimum 05 days. II. For, all server, Networking Device, Ups, Generator FAT/PSI will be conducted by 03 Engineers from BREB/PBS for minimum 05 days	Server, Networking device, Ups, Generator is not scope of work of this tender. Please clarify.	This clause has deleted.		
Section-05	116-123	<b>General</b> 1. The Price Schedules are divided into separate Schedules as follows: Schedule No. 1: Plant (including Mandatory Spare Parts) Supplied from Abroad Schedule No. 2: Plant (including Mandatory Spare Parts) Supplied from within the Employer's Country Schedule No. 3: Design Services Schedule No. 4: Installation and Other Services Schedule No. 5: Grand Summary Schedule No. 6: Recommended Spare Parts <b>Schedule of Rates and Prices</b> Schedule No. 1 - Plant and Mandatory Spare Parts Supplied 1-Phase Smart Prepayment Meter with RF Mesh Communication Module: <table border="1" style="display: inline-table; vertical-align: middle;"><tr><td>nos</td><td>25000</td></tr></table> Schedule No. 2 - Plant and Mandatory Spare Parts Supplied from within the Employer's Country- Not Applicable Schedule No. 4 - Civil works part- Not Applicable Schedule No. 5- Installation and Other Services-Not Applicable Schedule No. 6 - Grand Summary- Not Applicable Schedule No. 7 - Recommended Spare Parts- Not Applicable	nos	25000	1. There are discrepancies between Schedule Title. Please clarify and provide us appropriate Schedule number with Title. 2. Since this this National competitive tender we shall quote Schedule 1 or Schedule 2? Please clarify.	The schedule for price quoting is attached.
nos	25000					

*(Signature)*  
Date: 2024.08.29

*(Signature)*  
Date: 2024.08.29

52

Sub: Response against queries of Hexing Electrical Co., Ltd for Design, Supply, Testing and Commissioning of 25,000 Nos I-Phase Smart Prepayment Meter with RF mesh Communication Module.

Ref: Sub-Package No: 23-24-DHKPBS-1. O&M-01

Section/ Clause of TD	Page Number	Provision of tender document	Queries from Bidders	Response of BREB						
Section-05	124-125	<p><b>Technical Proposal (Form PG5A-4)</b> [The Revised Technical Proposal, if any, shall follow the same format and structure]</p> <p>Site Organization Method Statement Mobilization Structure Construction Structure Plant Safety Plan Personnel Equipment Proposed subcontractors for Major Items of Plant and Services Time Schedule</p>	<p>In case of Pre-Paid Meter Supply Tender only: Technical Proposal (Form PG5A-4) may not be required. Please clarify.</p>	<p>It is not applicable for this tender.</p>						
Section-05	126	<p><b>Personnel Information</b> [This Form should be completed for each person proposed by the Tenderer on Form PG5A-2a&amp; PG5A-2b, where applicable]</p> <table border="1"> <tr> <td>Invitation for Tender No:</td> <td>[indicate IFT No]</td> </tr> <tr> <td>Tender Package No</td> <td>[indicate Package No]</td> </tr> <tr> <td>This Package is divided into the following Number of Lots</td> <td>[indicate number of Lot(s)]</td> </tr> </table> <p><b>Equipment Information</b> [The Tenderer shall provide adequate information to demonstrate clearly that it has the capability to meet the requirements for the key equipment listed in TDS. A Separate Form shall be prepared for each item of equipment listed, or for alternative equipment proposed by the Tenderer]</p>	Invitation for Tender No:	[indicate IFT No]	Tender Package No	[indicate Package No]	This Package is divided into the following Number of Lots	[indicate number of Lot(s)]	<p>In case of Pre-Paid Meter Supply Tender only: Equipment Information may not be required. Please clarify.</p>	<p>It is not applicable for this tender.</p>
Invitation for Tender No:	[indicate IFT No]									
Tender Package No	[indicate Package No]									
This Package is divided into the following Number of Lots	[indicate number of Lot(s)]									
Section-05	127	<table border="1"> <tr> <td>Invitation for Tender No:</td> <td>[indicate IFT No]</td> </tr> <tr> <td>Tender Package No</td> <td>[indicate Package No]</td> </tr> <tr> <td>This Package is divided into the following Number of Lots</td> <td>[indicate number of Lot(s)]</td> </tr> </table>	Invitation for Tender No:	[indicate IFT No]	Tender Package No	[indicate Package No]	This Package is divided into the following Number of Lots	[indicate number of Lot(s)]	<p>In case of Pre-Paid Meter Supply Tender only: Equipment Information may not be required. Please clarify.</p>	<p>It is not applicable for this tender.</p>
Invitation for Tender No:	[indicate IFT No]									
Tender Package No	[indicate Package No]									
This Package is divided into the following Number of Lots	[indicate number of Lot(s)]									


১৯/০৬/২০২৪  
১৯/০৬/২০২৪  
১৯/০৬/২০২৪


১৯/০৬/২০২৪  
১৯/০৬/২০২৪  
১৯/০৬/২০২৪

**Sub: Response against queries of Hexing Electrical Co., Ltd for Design, Supply, Testing and Commissioning of 25,000 Nos 1-Phase Smart Prepayment Meter with RF mesh Communication Module.**

Ref: Sub-Package No: 23-24-DHKPBS-1. O&M-01

Section/ Clause of TD	Page Number	Provision of tender document	Queries from Bidders	Response of BREB
Section-06	143	The overall works of prepayment e-metering system divided into following 4 major areas: A. Software development for the system and maintenance service. B. Hardware Procurement, Installation and Commissioning C. Establishment of country wide secure and dedicated data-network service. D. Procurement, Installation and Commissioning of Prepayment Meter.	Please clarify the Scope of work.	Not applicable.
Section-07	219	ii) In case of Smart Pre-Paid Meter Supply, The manufacturer shall have Satisfactory Performance Certificate from the End User (must be from a Electricity Utility) with at least 2(Two) contracts of Supply of electric Pre-payment meter of which at least 1(one) from outside the manufacturer's own country during last 5 (five) calendar years. All certificates of End Users shall be in English in their letterhead pad where detail e-mail address, Telephone no., Fax no. etc will be furnished.	According to tender document only manufacturers from Bangladesh are eligible for tender and may not have "at least 1(one) experience from outside the manufacturer's own country during last 5 (five) calendar years" Please clarify and amend accordingly.	In case of Smart Pre-Paid Meter Supply, The manufacturer shall have Satisfactory Performance Certificate from the End User (must be from a Electricity Utility) with at least 2(Two) contracts of Supply of electric Pre-payment meter during last 5 (five) calendar years.
Section-04	100	<b>GCC 9.1</b> A Supplier is a national of or register in the following countries are not eligible: only Bangladesh are eligible Tender doesn't have provision to supply IT Goods and HES under the contract.	Which server will be used to deploy the HES & other applications and in which system will the meters be interfaced? If required to interface with an existing system, what will be the procedure? Please clarify.	The existing server will be used to install HES (if required)
N/A	N/A			

  
 মোহাম্মদ ফারুক হোসেন  
 গণকারণ (প্রশাসন)  
 মহাশক্তি নং-৫২৩২৩৭  
 ঢাকা পাবনা-১

  
 মোহাম্মদ আব্দুল জালিল মিয়া  
 ডিজিএম (সদর সত্তর-কারিগরি)  
 ঢাকা পাবনা-১

